

消防處
防火組
香港九龍尖沙咀東部康莊道1號
消防總部大廈



Registered Mail
FIRE SERVICES DEPARTMENT,
FIRE PROTECTION BUREAU,
FIRE SERVICES HEADQUARTERS BUILDING,
No. 1 Hong Chong Road,
Tsim Sha Tsui East, Kowloon,
Hong Kong.

本處檔號 Our Ref.: (12) in FPB 206/0435
AL162096-1
來函檔號 Your Ref.:
電訊掛號 Telex: 39607 HKFSD HX } (24 小時 Hours)
圖文傳真 Fax: 852-723 2197 }
電話 Tel. No.: 2733 7744

29 March 1996

Henry Engineering & Supplies
3/F., Cheong Tai Commercial Building,
287-289, Reclamation Street,
Kowloon, Hong Kong.

Dear Sir,

Application for the Approval of
"Badger" Dry Chemical Extinguisher

I refer to my interim reply of 26.2.1996 on the captioned subject.

The proposed use of the following wheeled fire extinguishers, which are certificated by Underwriters Laboratories Inc. (UL), is acceptable to this Department:-

Manufacturer : Badger-Powhattan
Type : Wheeled Dry Chemical Fire Extinguisher
Operating Method : Stored Pressure

	<u>Model</u>	<u>Capacity</u>	<u>Agent</u>	<u>Fire Rating</u>
i)	150MB	125 lb. (56.7 kg)	ABC Powder (Ammonium Phosphate)	40A:240-B:C
ii)	150PB	125 lb (56.7 kg)	Purple-K (Potassium Bicarbonate)	240-B:C
iii)	150RB	150 lb (68 kg)	Regular (Sodium Bicarbonate)	240-B:C

Testing Standard : UL 299 and UL 711
Test Report : File Ex2102 Project 86NK21847 dated 4.1.1988 issued by UL

Please note that all fire extinguishers must be clearly marked with the operating instructions in both English and Chinese characters.

Yours faithfully,

(LAM Chun-man)
for Director of Fire Services