



本處接獲 Our Ref: (10) in FPB 206/0835
來函編號 Your Ref: BF-L4332/L1-94
電話號碼 Tel: 39607 HXFSO-HX } (24 小時 Hours)
圖文傳真 Fax: 852-723 2197
電 傳 Telex No: 2733 7744

9 March 1995

Application for Approval of
"SRI" Range of Fire Extinguishers

I refer to your letter dated 16.2.1995 on the captioned subject.

Pursuant to Regulation 3 of the Fire Service (Installations and Equipment) Regulations, Chapter 95, Laws of Hong Kong, approval is hereby given to the following portable fire extinguishers for sale or supply in Hong Kong :-

Manufacturer : Steel Recon Industries Sdn. Bhd.
Brand Name : SRI
Operating Method : Stored Pressure


<u>Type</u>	<u>Model No.</u>	<u>Capacity</u>	<u>Rating</u>
ABC Powder	FEX 173	1.0 kg	3A
ABC Powder	FEX 159	2.0 kg	5A
ABC Powder	FEX 131	4.5 kg	13A/55B
ABC Powder	FEX 171	6.0 kg	21A/55B
ABC Powder	FEX 132	9.0 kg	21A/89B
Carbon Dioxide	FEX 140	4.5 kg	21B

Test Report : SL950046 - SL950050 dated 27.1.1995 and
SL950079 dated 14.2.1995, issued by
Standards and Industrial Research
Institute of Malaysia.

The above-mentioned extinguishers will be listed in the Hong Kong Government Gazette.

Please note that all fire extinguishers must be clearly marked with the operating instructions in both English and Chinese characters.

Yours faithfully,


(ISA)K Kwong-yu
for Director of Fire Services

Ref. number and date should be quoted in reference to this letter
凡提及本信時請引述編號及日期

TKZ/WSC/KMS/c1