

消 防 處  
牌 照 及 審 批 總 區  
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓  
消 防 總 部 大 廈



FIRE SERVICES DEPARTMENT  
LICENSING AND CERTIFICATION  
COMMAND

FIRE SERVICES HEADQUARTERS BUILDING,  
No.1 Hong Chong Road, 5/F,  
Tsim Sha Tsui East Kowloon,  
Hong Kong.

號 OUR REF.: (64) in FP 206/0855 II

號 YOUR REF.: SY 0733/01

號 TELEX:39607 HKFSD HX

件 E-mail <lcpolice2@hkfsd.gov.hk>

真 FAX: 852-2723 2197

話 TEL NO.: 2733 7744

30 November 2001

Henry Engineering & Supplies  
O/B Good Stride Limited  
3/F, Cheong Tai Commercial Building,  
287-289 Reclamation Street, Kowloon,  
Hong Kong.

Dear Sirs,

Approval of Portable Fire Extinguisher

I refer to my interim reply of 24.9.2001 on the captioned subject.

Pursuant to Regulation 3 of the Fire Service (Installations and Equipment) Regulations, Chapter 95, Laws of Hong Kong, I hereby approve the following fire extinguishers for sale and supply in Hong Kong :

Manufacturer	:	Steel Recon Industries Sdn Bhd
Testing Standard	:	BS EN 3 : 1996
Testing Organization	:	British Standards Institution (BSI)
i) Model	:	FEX 182
Type & Size	:	2 kg Carbon Dioxide
Fire Rating	:	34B
Supporting Document	:	Test Report No. 285/4174568 Model FEX182 issued by BSI on 4.9.2001.
ii) Model	:	FEX 183
Type & Size	:	5 kg Carbon Dioxide
Fire Rating	:	55B
Supporting Document	:	Test Report No. 285/4174568 Model FEX183 issued by BSI on 4.9.2001.


- iii) Model : FEX 101  
Type & Size : 9 litre water, stored pressure (12 bar)  
Fire Rating : 13A  
Supporting Document : Test Report No. 285/4174568 Model FEX101 issued by BSI on 4.9.2001.
- iv) Model : FEX 102  
Type & Size : 6 litre foam, stored pressure (12 bar)  
Fire Rating : 8A, 113B  
Supporting Document : Test Report No. 285/4174568 Model FEX102 issued by BSI on 4.9.2001.
- v) Model : FEX 103  
Type & Size : 9 litre foam, stored pressure (12 bar)  
Fire Rating : 13A, 183B  
Supporting Document : Test Report No. 285/4174568 Model FEX103 issued by BSI on 4.9.2001.
- vi) Model : FEX 104  
Type & Size : 2 kg ABC powder, stored pressure (14 bar)  
Fire Rating : 13A, 55B  
Supporting Document : Test Report No. 285/4174568 Model FEX104 issued by BSI on 6.9.2001.
- vii) Model : FEX 105  
Type & Size : 4 kg ABC powder, stored pressure (14 bar)  
Fire Rating : 21A, 113B  
Supporting Document : Test Report No. 285/4174568 Model FEX105 issued by BSI on 4.9.2001.

- viii) Model : FEX 106
- Type & Size : 6 kg ABC powder, stored pressure (14 bar)
- Fire Rating : 27A, 144B
- Supporting Document : Test Report No. 285/4174568 Model FEX106 issued by BSI on 4.9.2001.
- ix) Model : FEX 107
- Type & Size : 9 kg ABC powder, stored pressure (14 bar)
- Fire Rating : 34A, 233B
- Supporting Document : Test Report No. 285/4174568 Model FEX107 issued by BSI on 4.9.2001.

The above fire extinguishers will be published in the Government Gazette.

Please note that the operating instructions in Chinese and English characters shall be used on all fire extinguishers.

Yours faithfully,



(LAU Kwai-shan)  
for Director of Fire Services