

消 防 處  
牌 照 及 審 批 總 區

香港九龍尖沙咀東康莊道1號5樓  
消防總部大廈



FIRE SERVICES DEPARTMENT  
LICENSING AND CERTIFICATION  
COMMAND

FIRE SERVICES HEADQUARTERS BUILDING,  
5/F, No.1 Hong Chong Road,  
Tsim Sha Tsui East Kowloon,  
Hong Kong.

本處檔號 OUR REF.: (9) in FP 206/0855 III  
來函檔號 YOUR REF.: CCT0117/03  
電報掛號 TELEX:39607 HKFSD HX  
電子郵件 E-mail <lcpolice2@hkfsd.gov.hk>  
圖文傳真 FAX: 852-2723 2197  
電 話 TEL NO.: 2733 7744

23 May 2003

Henry Engineering & Supplies  
O/B Good Stride Limited  
3/F, Cheong Tai Commercial Building,  
287-289 Reclamation Street, Kowloon,  
Hong Kong.

Dear Sirs,

**Approval of Portable Fire Extinguishers**

I refer to my interim reply of 28.3.2003 on the captioned subject.

Pursuant to Regulation 3 of the Fire Service (Installations and Equipment) Regulations, Chapter 95, Laws of Hong Kong, I hereby approve the following fire extinguishers for sale and supply in Hong Kong :

<b>Manufacturer</b>	:	Steel Recon Industries Sdn Bhd
<b>Testing Standard</b>	:	BS EN 3 : 1996
<b>Testing Organization</b>	:	BSi Product Services
<b>i) Model</b>	:	FEX 108
<b>Type &amp; Size</b>	:	1 kg ABC powder (stored pressure)
<b>Body Material</b>	:	Steel
<b>Fire Rating</b>	:	5A:21B
<b>Supporting Document</b>	:	Test Report No. 285/4359690 Model FEX108 issued by BSi Product Services on 11.3.2003.


.../P.2

- Manufacturer** : Steel Recon Industries Sdn Bhd
- Testing Standard** : BS EN 3 : 1996
- Testing Organization** : BSi Product Services
- ii) **Model** : FEX 111
- Type & Size** : 9 litre water (CO<sub>2</sub> gas cartridge)
- Body Material** : Steel
- Fire Rating** : 13A
- Supporting Document** : Test Report No. 285/4359690 Model FEX111 issued by BSi Product Services on 11.3.2003.
- iii) **Model** : FEX 112
- Type & Size** : 9 litre foam (CO<sub>2</sub> gas cartridge)
- Body Material** : Steel
- Fire Rating** : 13A:183B
- Supporting Document** : Test Report No. 285/4359690 Model FEX112 issued by BSi Product Services on 11.3.2003.

The above fire extinguishers will be published in the Government Gazette.

Please note that operating instructions in both Chinese and English shall be delineated on all fire extinguishers.

Yours faithfully,



(LAU Kwai-shan)  
for Director of Fire Services